

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7271-1130:162 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Honeywell, Inc., 1500 W..Dundee Road, Arlington Heights IL 60004-1472
Contact: Bob Hodgson (847) 797-4403

DESIGN: Model TC805C 1000 and TC805C 1018 smoke detectors. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as an ionization smoke detector for use with separately listed compatible fire alarm control units and Model TC805C-1018 is intended for use with Model DH400 series duct detector housing.

XLF: 7271-1209:126

10-17-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager